

SAFE DRINKING WATER CERTIFICATE


No. 9

Date: 02-5-2025

It is certified that an inspection team headed by Mohinder Singh
J. E. Jal Shakti Vibhag Bharoli (Name of Officer with
Designation) from Sub Division Jwalamukhi (Name of Department
/ Office) inspected the VedDhara Global School, Vill.-Dhanot, P.O.- Adhwani, Teh. – Jwalamukhi,
Distt.- Kangra (H.P.) 176036 on 30-04-2025 and found the VedDhara
Global School has safe drinking water facilities for the students and members of staff of the
institution in the school building & campus as per the norms prescribed by the Central /State/U.T.
Govt.

The above valid for the period of One year

Signature with Seal : 

Name : Mohinder Singh 

Designation : Junior Engineer JSY
Section Bharoli

To

VedDhara Global School

Vill.-Dhanot, P.O.-Adhwani, Teh.-Jwalamukhi,

Distt.-Kangra (H.P.) 176036.

**HIMACHAL PRADESH
JAL SHAKTI VIBHAG
WATER TESTING LABORATORY DEHRA**

Email: - dehralab@gmail.com	Mob.No. 7018995593	Sr. No. 1354
-----------------------------	--------------------	--------------

Detail of the Sample :- Ved Dhara Globel School Vill Dhanot PO Adhwani Tehsil J/ Mukhi

Name of the Scheme:- Private Sample

Date & Time of the Collection . 27-08-2025

Date & Time of Report at Lab. 27-08-2025

Date & Time of Commencing of test. 28-08-2025

A.PHYSICAL PARAMETERS(Limits: Based upon :10500-2012)

1	2	3	4	5	6
S.No	Test Parameter	Units	Acceptable Limit	Permissible Limit	Test Result
1	Colour	Hazen Units	5	15	0
2	Odour		Agreeable	Agreeable	Agreeable
3	Taste		Agreeable	Agreeable	Agreeable
4	Turbidity	NTU	1	5	0.87
5	pH		6.5-8.5	No relaxation	7.42

B.Chemical Parameters (Limits : Based upon BIS:10500-2012)

6	TDS /Elec.Conductivity	Mg/L	500	2000	240
7	Total Alkalinity	Mg/L	200	600	186
8	Chloride	Mg/L	250	1000	28.36
9	Calcium	Mg/L	75	200	48
10	Magnesium	Mg/L	30	100	14.88
11	Total Hardness	Mg/L	200	600	182
12	Free Residual Chlorine	Mg/L	0.2	1	0.2
13	Total Coli forms	Number/100ml	Nil	Nil	Nil

Note: Indicate discrete sampling. Water quality monitoring to be continued only if these are traced in drinking water sources.

1. Sample will be stored for a period of 3 day from the date of issue of report.
2. Result refers only to tested samples and parameters tested.
3. This report should not be produced partially or fully without approval of the signatory for legal purposes.
4. 12 and 13 test parameters are not recognized by the NABL body.


Assistant Engineer
JSV Sub-Division Dehra
JM